

Bid Package 2 | Addendum No. 3
for
Construction of
St. Croix County Health Center Additions and Renovation
Project No. 146038

Date: July 16, 2015

Bids for Bid Package 2 due: Friday, July 24, 2015 at 2:00 p.m. (CST)

Bidders must use the proper Bid Form and send it directly to St. Croix County.

NOTE: This Addendum may apply to any or all contracts and/or subcontracts.

ATTACHMENTS

The following document(s) hereby become a part of this Addendum, the Bidding Documents, and the Contract Documents for the Project.

SHEET A108, rev. #1
SHEET A304, rev. #1

DRAWINGS

SHEET A108, rev. #1

Detail 7/A108 – Add detail reference to shower of Resident Toilet room SN D2.

Detail 3A/A108 – Revise detail reference at shower to 5C/A401 at Resident T room DCS A2.

SHEET A304, rev. #1

Detail 4C/A304 – Revise detail reference at shower to 5C/A401.

PROJECT MANUAL

SECTION 22 43 00 HEALTHCARE PLUMBING FIXTURES (not reissued)

Add to Section 2.1 Plumbing Fixtures, Trim and Specialties A.:

P-4A Alternate No. 6 Fixtures:

For Area D, CBRF Building, First and Second floor:

Salo 148-34H BF/Aquatic/BestBath. One piece fiberglass shower stall with gelcoat finish, plywood backing for grab bars and future seat, 1 inch nailing flange, handicap accessible barrier-free with ¾ inch maximum threshold. Flame spread rating: less than 75 in accordance with ASTM E 162. Smoke generation: less than 450 in accordance with NFPA 258. Furnish three 1-

1/4" diameter stainless steel grab bars as shown on architectural interior details, furnish shower curtain rod of 1" OD stainless steel with mounting brackets, and collapsible T-shaped EPDM rubber water stopper with large end caps. Shower unit measures 48" x 37" x 78-7/8" high outside, 46" x 34-1/2" clear inside, provide right and left hand plumbing. Color shall be white.

For Area A, B and C, first floor:

Salo 162H BF/Aquatic/BestBath. One piece fiberglass shower stall with gelcoat finish, plywood backing for grab bars and future seat, 1 inch nailing flange, handicap accessible barrier-free with 3/4 inch maximum threshold. Units in accessible rooms shall be furnished with folding transfer seat as shown on architectural unit enlarged plans. Other units shall have no seat. Flame spread rating: less than 75 in accordance with ASTM E 162. Smoke generation: less than 450 in accordance with NFPA 258. Furnish three 1-1/4" diameter stainless steel grab bars as shown on architectural interior details, furnish shower curtain rod of 1" OD stainless steel with mounting brackets, and collapsible T-shaped EPDM rubber water stopper with large end caps. Shower unit measures 62" x 39" x 78-7/8" high outside, 60" x 36" clear inside, provide right and left hand plumbing. Color shall be white.

APPROVED EQUALS

The following manufacturers have applied for "or equal" approval and their quotation(s) may be used by contractors when bidding the Project. It is the duty of the contractor to ascertain that the equipment, workmanship, and products offered do indeed meet the specifications in all respects since this approval does not waive any part of the specification, but indicates that the Bidder has shown he understands the specification and is able to provide equipment, workmanship, and products to fulfill those requirements and can adapt to building dimensions.

Section No.	Item	Manufacturer
09 51 13	2.3.B	USG "Olympia Micro Climaplus" #4211
09 51 13	2.3.C	USG "Radar Climaplus" #2210
09 51 13	2.3.D	USG "Sheetrock Lay-in Climaplus" #3260

End

